

Licensed Asbestos Removalist Self-Assessment Tool

This self-assessment tool is for Licensed Asbestos Removalists to ensure they are complying with legislation, to prepare for upcoming site audits conducted as part of the Construction Priority Harms Campaign. This checklist contains questions like the ones on the audit tool used by our Inspectors.

Licensed Asbestos Removalist	Compliant	Comments	Legislative Reference
<p>Does your Asbestos Removal Control Plan (ARCP) detail the asbestos to be removed, including the location, type and condition of the asbestos?</p>	<p>Yes No</p>		<p>Regs: 464</p>
<p>Does your ARCP detail how the asbestos removal will be carried out?</p> <p><i>It must include:</i></p> <ul style="list-style-type: none"> » the method to be used » the tools, equipment and personal protective equipment to be used » decontamination 	<p>Yes No</p>		<p>Regs: 464</p>
<p>Does the type and quantity of asbestos listed in your ARCP match the notification given to SafeWork SA?</p>	<p>Yes No</p>		<p>Act: S 268</p>
<p>Have you provided a copy of the ARCP to the Person Who Commissioned Work (PWCW)?</p> <p><i>Please note: this is an expiable offence.</i></p> <p><i>Providing a copy of the ARCP to the PWCW ensures both parties have a clear understanding of the scope, methods, and safety measures before work begins, reducing the risk of misunderstandings or unsafe practices.</i></p>	<p>Yes No</p>		<p>Regs: 464 (3)</p>

Has an independent licensed asbestos assessor been engaged to undertake air monitoring and provided a clearance certificate?	Yes	No	Regs: 475
Have you obtained a copy of the asbestos register? <i>(not applicable for residential)</i>	Yes	No	Regs: 463
Is the ARCP available to all relevant parties including workers?	Yes	No	Regs: 464
Have you (the license holder) notified people in the vicinity of the area, prior to works commencing? <i>i.e neighbours, owners, PWMC.</i>	Yes	No	Regs: 467
Are you using signage and barricades suitable for the type of removal work being undertaken?	Yes	No	Regs: 469
Have you provided decontamination facilities (suitable for the type of work)?	Yes	No	Regs: 471
Do you have records of the relevant training certificates (for all workers involved the removal) on site? <i>Please note: this is an expiable offence</i>	Yes	No	Regs: 461
Do you have an industrial H Class vacuum cleaner available for use and in good condition?	Yes	No	Regs: 35, 213 S:60335.2.6: 2003
Is the industrial H class vacuum cleaner in current electrical test and tag date? (3 monthly) <i>Please note: this is an expiable offence</i>	Yes	No	

Licensed Asbestos Removal Workers	Compliant		Comments	Legislative Reference
Have all your workers completed general construction induction training (White Card)? <i>Please note: this is expirable to the PCBU</i>	Yes	No		Regs: 316
Is the authorised supervisor present (Class A) and/or available to workers on site (Class B)? <i>Supervisor must be available for non-friable, within 20 minutes. Supervisor must be on site for friable.</i>	Yes	No		Regs: 459, 529
Have your workers been fit tested for the type of tight-fitting respirator being used?	Yes	No		Regs: 44
Have your workers undertaken health monitoring within the last 2 years?	Yes	No		Regs: 435

For more information:

- [Asbestos – SafeWork SA](#)
- [How to safely remove asbestos Code of Practice – SafeWork SA](#)



Government
of South Australia

SafeWork SA